



Industrie Service

Mehr Wert.  
Mehr Vertrauen.

# Hygiene evaluation

(short version)

with regard to the observance of hygiene requirements  
in accordance with VDI 6022-1 (01/ 2018)  
on the air handling unit CW050

manufactured by

*Guangdong Cold Magic Air-conditioning Equipment Co.,Ltd.No.22 Cuishanhu Road,  
Cuishanhu New District , Kaiping City, Guangdong Province, China*

## OBJECT OF THE EVALUATION

A report was prepared on behalf of Guangdong Cold Magic Air-conditioning Equipment Co.,Ltd.No.22 Cuishanhu Road, Cuishanhu New District , Kaiping City, Guangdong Province, China in which the observance of hygiene requirements in compliance with VDI 6022-1 (01/2018) was reviewed. An air handling unit CW050 (AHU) was assessed.

In preparing this report, the components in the series were inspected online in the factory of Guangdong Cold Magic Air-conditioning Equipment Co.,Ltd.No.22 Cuishanhu Road, Cuishanhu New District , Kaiping City, Guangdong Province, China; data sheets, technical documentation, test reports and other reports were examined and assessed.

## Conclusion

The components and the documents listed for the air handling unit CW050 (AHU) made by Guangdong Cold Magic Air-conditioning Equipment Co.,Ltd.No.22 Cuishanhu Road, Cuishanhu New District , Kaiping City, Guangdong Province, China can meet the hygiene requirements of VDI 6022-1 after changes.

The detailed report in German dated 02/28/2022 is binding.

The report is valid until 01/2027 or if substantial changes are made to the series tested.

Ravensburg, 03/09/2022

Senior Expert



Dipl.-Ing. (FH) Peter Hofmeister